



Biofuel Local Supply, Storage and Risk Study

Questions:

1. Can you confirm whether our proposal would be valid considering that we missed the deadline to submit an intent to respond form?

Yes, your proposal will still be valid, provided that it is submitted by the time and date stated in the tender document.

2. Could you provide further specifics on the gensets you have, including make, model and capacity?

AREA does not currently own any gensets. We are focussed on used diesel genset, that over a period of time can be built up to 33MW.

3. Could you clarify what fuel(s) these gensets currently use or have recently used? E.g. diesel, other?

The gensets we are considering at this stage, use diesel.

4. Could you provide some information on the target energy load in MW that your gensets provide? The RFP document refers to the peak load of 33MW but it does not specify what portion of that peak load is met by the renewable electricity assets vs the peak load gensets.

AREA intends to determine if we can reliably run 33 MW gensets on biofuels.